

Avantha Centre for Industrial Research & Development

(Partners in Industrial Progress)

Paper Mill Campus, Yamuna Nagar - 135 001, Haryana, INDIA

Tel. : +91-1732-292703/ 704
Fax : +91-1732-292748Email : csc@avantharesearch.org
URL : www.avantharesearch.org

AVANTHA


TEST REPORT

Customer's Address	M/s. Satia Industries Limited, Village Rupana, Distt. Sri Muktsar Sahib - 152 038 (Pb.) Kind Attn.: Mr. S. M. Rao	Report No.	16/ACIRD/362
		Date	18.03.2017
		PI No. & Date	E36201 dated 16.03.2017
		Party's Ref.	Email dated 15.03.2017
Sample Description	Effluent sample submitted by customer	Receipt Date	16.03.2017
		Date of Start	16.03.2017
		Date of Completion	17.03.2017
		No. of Sample(s)	01

TEST RESULTS

S. No.	Sample ID	Test Parameter(s)	Unit	Result	Test Method
01	Final Treated Effluent dated 16.03.2017	Sodium Adsorption Ratio (SAR)	-	6.17	APHA:3111 B & USEPA (Part -15)
02		Adsorbable Organic Halogen (AOX)	mg/L	14.0	ISO:9562
03		Colour (at pH: 7.61 & temp : 25°C)	Pt-Co	276	APHA:2120 C

End of Report


(Dr. Nishi Kant Bhardwaj)
Authorized Signatory

This report contains ONE page(s) only

For Satia Industries Ltd.

Authorized Signatory

Note 1:

- The above results refer only to the tested sample(s) and applicable parameters submitted by customer; Endorsement of products is neither inferred nor implied.
- Samples will be destroyed after one month from the date of issue of test report unless otherwise specified.
- The report is not to be reproduced wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without special permission in writing.
- In case any reconfirmation of contents of the test report is required, please contact the authorized signatory of the test report within 15 days of the issue of the report.

Note 2: The feedback form is attached. Please fill the same and revert to the authorized signatory so that we can improve upon our services.